

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Code Change Cycle:

2010 Triennial Original Modification 3/1/2010 4/2/2010

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

202

3873 - **ACTION-TABLED - REMOVED FROM TABLE = ACTION - APPROVED AS SUBMITTED-**

Florida specific mod to IBC flood provisions. Sec. 1612 and CCCL Sec 3109 use "substantial improvement" with different dfns. . FL Div Emerg Mgnt will coordinate a group with FBC and DEP to consider changes for future cycle.

Rebecca Quinn

2

Comment

Proponent

Summary

Mod #

Section

Chapter

202

3874 - **ACTION - NOT SUPPORTED**

Retain base code (IBC) language as it provides better direction.

J Glenn BASF

2

Comment

Proponent

Summary

Mod #

Section

Chapter

202

4314 **ACTION - NOT SUPPORTED (NOT ON LIST)**

Updates the definition of Habitable Space to include revised information from AAMA/NPEA/NSA 2100 10 for sunrooms. This document now defines a Category IV sunroom as a non habitable space.

Daniel Walker

2

Comment

Proponent

Summary

Mod #

Section

Chapter

202

4332 **ACTION - ALTERNATE PROPOSAL A-1 APPROVED AS AMENDED ICC-ACTION**

Includes Tubular Daylighting Devices in definition of unit skylights

Chuck Anderson

2

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

801.5

3882 **ACTION - BETTER LANGUAGE ON 4398 - NOT APPROVED**

Florida specific modifications to Chapter 8, related to retaining flood provisions of the I Codes which require materials below the DFE to be flood damage resistant materials specified in 1612.4 by reference to ASCE 24.

Rebecca Quinn

8

Comment

Proponent

Summary

Mod #

Section

Chapter

801.5

4398 **ACTION - APPROVED AS SUBMITTED**

Clarify the elevation below which flood damage resistant materials are required is the elevation specified in 1612.4.

Christopher Jones

8

Comment

Proponent

Summary

Mod #

Section

Chapter

1202.1

4109 **ACTION - APPROVED AS SUBMITTED**

The modifications clarify that roofs of sunrooms without sloped glazing are solid roofs and clarifies open areas are areas with operable windows or fixed glass or glass doors. The clarifications are needed to address confusion demonstrated during the permitting phase for sunroom projects.

Joseph Belcher

12

Comment

Proponent

Summary

Mod #

Section

Chapter

1203.3.2

3986 **ACTION - APPROVED AS SUBMITTED**

1. Delete Florida Specific amendment to 1203.3.2 and retain IBC language.
2. Change code reference to Chapter 13 of the Florida Building Code, Building
3. Retain exception #5 and renumber to #6.

J Glenn BASF

12

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

1210.3

3989 **ACTION - APPROVED AS SUBMITTED**

Delete Florida Code language to 1210.2 and retain IBC language with the accessibility requirement in exception #2.

J Glenn BASF

12

Comment

Proponent

Summary

Mod #

Section

Chapter

1403.2

3909 **ACTION - APPROVED AS SUBMITTED**

Delete Florida Code language to 1403.2 and retain IBC language.

J Glenn BASF

14

Comment

Proponent

Summary

Mod #

Section

Chapter

1403.5

3883 **ACTION - 4399 AND NOT THIS ONE**

Florida specific modifications to 1403.5, related to retaining flood provisions of the I Codes which require materials below the DFE to be flood damage resistant materials specified in 1612.4 by reference to ASCE 24.

Rebecca Quinn

14

Comment

Proponent

Summary

Mod #

Section

Chapter

1403.5

4399 **ACTION - APPROVED AS SUBMITTED**

Clarify the elevation below which flood damage resistant materials are required is the elevation specified in 1612.4.

Christopher Jones

14

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

1403.7

3998 **ACTION - APPROVED AS SUBMITTED**

Retain Florida Specific language

J Glenn BASF

14

Comment

Proponent

Summary

Mod #

Section

Chapter

1404

3856 **ACTION - (1715-9) TABLED FOR 3231= APPROVED AS SUBMITTED**

Adds reference to new section on labeling of soffits.

Joseph Belcher

14

Comment

Proponent

Summary

Mod #

Section

Chapter

1404.10

3914 **ACTION - APPROVED AS SUBMITTED**

Change 1404.10 to correct terminology and reference the proper type of material.

J Glenn BASF

14

Comment

Proponent

Summary

Mod #

Section

Chapter

1404.2

3912 **ACTION - APPROVED AS SUBMITTED**

Change 1404.2 to include language from IBC and add "Florida Specific language. Retain Florida Specific Language in Section 1404.2.1

J Glenn BASF

14

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

1404.9

3913 **ACTION - APPROVED AS SUBMITTED**

Change 1404.9 title to include soffit and to include language from IBC and add "Florida Specific language." Retain Florida Specific Language in Section 1404.9.1

J Glenn BASF

14

Comment

Proponent

Summary

Mod #

Section

Chapter

1405

4215 **ACTION - TABLED-ACTION - APPROVED AS MODIFIED WITH LAST CHANGE (# 4214) THIS MODIFICATION ADDRESSES BRICK DESIGN WIND SPEEDS AND ACI 530 ACTION - APPROVED AS SUBMITTED, BRICK ABOVE 150 NEEDS TO BE ENGINEERED**

This modification is a correlation to the modification that updates ASCE 7 to the 2010 Edition and introduces new ultimate design wind speed maps in the code.

T Stafford

14

Comment

Proponent

Summary

Mod #

Section

Chapter

1405.1

4466 **ACTION - APPROVED AS SUBMITTED-ACTIN TO STRIKE TIME SIGN APPROVED AS MODIFIED (X SIGN)**

Proosal eliminates wind load provisions of AAMA 1402 which are contrary to the wind load provisions of the code.

Joseph Belcher

14

Comment

Proponent

Summary

Mod #

Section

Chapter

1405.10

4002 **ACTION - APPROVED AS SUBMITTED**

Change 1405.10 to retain base code (IBC) language.

J Glenn BASF

14

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

1405.11.4

4003 **ACTION - APPROVED AS SUBMITTED**

Change 1405.11.4 to retain base code (IBC) language.

J Glenn BASF

14

Comment

Proponent

Summary

Mod #

Section

Chapter

1405.14.1

4004 **ACTION - APPROVED AS SUBMITTED**

Change 1405.14.1 to retain base code (IBC) language.

J Glenn BASF

14

Comment

Proponent

Summary

Mod #

Section

Chapter

1405.3.2

3999 **ACTION - APPROVED AS SUBMITTED**

Change 1405.3.2 to retain IBC language

J Glenn BASF

14

Comment

Proponent

Summary

Mod #

Section

Chapter

1405.4

4000 **ACTION - APPROVED AS SUBMITTED**

Change 1405.4 to retain IBC language.

J Glenn BASF

14

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

1405.8

4001 **ACTION - APPROVED AS SUBMITTED**

Change 1405.8 to retain IBC language.

J Glenn BASF

14

Comment

Proponent

Summary

Mod #

Section

Chapter

New 1504.9

4374 **ACTION - NOT APPROVED STANDARD NOT AVAILABLE FOR REVIEW**

The code currently requires that garden and landscaped roofs be evaluated for wind resistance. This new section proposes a design guide to be used for this purpose.

Mike Ennis

15

Comment

Proponent

Summary

Mod #

Section

Chapter

1601.1, 1612

3885 **ACTION - APPROVED AS MODIFIED BY JACK GLENN TO STRIKE LANGUAGE FOR CLARIFICATION**

Florida specific mods to Chpt 16, retain I Code flood provisions. Defines 'local floodplain management ordinance' where communities will adopt FIRMs and higher stnds for NFIP Community Rating System. FBC requested statutory authority so that local higher stnds do not sunset every 3 years.

Rebecca Quinn

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1602, 1603, 1605, 1609, 1620

4214 **-ACTION - TABLED-2ND DAY-MODIFIED-ACTION - ACTION - APPROVED AS MODIFIED**

This proposal updates ASCE 7 to the 2010 Edition and introduces new ultimate design wind speed maps in the code.

T Stafford

16

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

1602.1 Definitions

3687 **ACTION - FAILED**

Add the requirement that exterior mounted cooling towers, fluid coolers, and evaporative condensers, which are subjected to wind forces be designed as a structure, to the FBC Building Code, volume.

Mark Speckin

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1603.1.4 Wind design data

3688 **ACTION - FAILED**

Add the requirement that the wind load requirement of Other Structures in terms of psf be shown on the Construction Documents

Mark Speckin

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1609.1

3857 **ACTION - TABLED = APPROVED AS SUBMITTED**

Adds reference to new section on Soffit labeling.

Joseph Belcher

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1609.1.1

4177 **ACTION - APPROVED AS SUBMITTED**

This modification deletes language that, due to a glitch in ASCE 7, could result in low and erroneous roof uplift pressures for higher sloped roofs.

T Stafford

16

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

1609.1.2

3677 **ACTION - [ON MOD & REVISED MOD.] - JOE BELCHER-AND ADDING ASTM E331 AND DELETING THE OTHER STANDARDS=FAILED-
ADMENDMENT FAILED OR MOD - FAILED**

This section is modified to imply that all openings into a roof structure, whether vertical or horizontal, need to be protected in the event of a hurricane or high event from debris as well as wind and rain. This will reduce structural, wind, water, and personal belonging damage in such an event.

Michael Hemmer

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1609.1.2

4232 **ACTION - APPROVED AS SUBMITTED**

The proposal adds and Exception from impact protection for screen or removable vinyl and acrylic wind panels on exterior balconies and porches.

Joseph Belcher

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1609.1.2.1

4033 **ACTION - APPROVED AS SUBMITTED**

Adds to standard to section 1609.1.2.1 Louvers. Louvers protecting intake and exhaust ventilation

Amanda Hickman

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1609.1.3

4447 **ACTION - NAR-LACK OF JUSTIFICATION FLORIDA SPECIFIC**

Delete section 1609.1.3 in its entirety without substitution.

Kurt Roeper

16

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

1609.4.3

3665 -**ACTION - APPROVED AS SUBMITTED-**

Clarify the intent of Section 1609.4.3 with regard to the 20% increase in uplift load regarding roof to wall connection.

Mo Madani

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1612

3891 -**ACTION - APPROVED AS SUBMITTED-**

Florida specific modifications to Chapter 16, related to retaining flood provisions of the I Codes. The Flood Resistant Standards Workgroup recommended a table to show where all flood provisions are located.

Rebecca Quinn

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1612.5

4397 -**ACTION - NAR**

Modifies a provision to be consistent with NFIP, ASCE 7, and ASCE 24, to use language that is consistent with structural design and loads.

Christopher Jones

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1618.4.6.1 and 1618.4.6.2

3664 -**ACTION - NAR-**

Coordinate structural design criteria for pedestrian guards and handrails between HVHZ and non HVHZ for non wind related loading.

Thomas Sputo

16

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

1618.4.6.3

3725 - **ACTION - APPROVED AS SUBMITTED**

Correlates the HVHZ requirements on use of laminated glazing for glass railings used in the wind borne debris region with those of the 2009 IBC.

Jaime Gascon

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1618.9

3841 - **ACTION - APPROVED AS SUBMITTED-**

Clarification of required design Flood Loads of ASCE 7

Mohammed Shaikh

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1620

4143 - **ACTION - APPROVED AS AMENDED -MODIFIED -**

ASCE 7 05 commentary states that high uplift may exist on rooftop equipment, but no methodology is given. Load calculations may vary by a large factor based on two methods given. This modification is to eliminate such differences and include uplift and revised lateral forces based on FIU research.

Arindam Gan Chowdhury

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1622

4331 - **ACTION - TABLE-ACTION - MODIFIED - TABLED 2ND TIME- WITHDRAWN**

The modification adds design wind pressures for aluminum screened enclosures developed from wind tunnel testing sponsored by the Aluminum Association of Florida.

Joseph Belcher

16

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

1622.1

4296 - **ACTION - APPROVED AS SUBMITTED-**

Modification proposes use of AAF Guide to Aluminum Construction in High Wind Areas by designers in the HVHZ.

Joseph Belcher

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1626.1

4347 - **ACTION - APPROVED AS SUBMITTED-**

Adds provisions allowing the enclosure of balconies or porches with screen or removable vinyl or acrylic panels with invoking opening protection requirements.

Joseph Belcher

16

Comment

Proponent

Summary

Mod #

Section

Chapter

Table 1609.7(1)

3650 - **ACTION - TABLED - ACTION - NAR AS SUBMITTED-NEEDS TO CORRECT AND RE-SUBMIT**

Wind load values have been revised based on ASCE 7 10 provisions.

Joseph Hetzel

16

Comment

Proponent

Summary

Mod #

Section

Chapter

1714.5.3.3.2

4448 - **ACTION -NAR**

Delete section 1714.5.3.3.2 in its entirety without substitution.

Kurt Roeper

17

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

1715.5.3

3631 - **ACTION - APPROVED AS SUBMITTED**

Moves section 1715.5.3.3.1 on glazed curtain wall, window wall and storefront systems to a new section 1715.5.6; moves remaining 'exception' in 1715.5.3.3.1 to 1715.5.3 Exterior Door Assemblies.

Jaime Gascon

17

Comment

Proponent

Summary

Mod #

Section

Chapter

1715.5.3.3.1

4179 - **ACTION - NAR**

This section deals with glazed curtain walls, window wall and storefront systems; it is currently hidden as a subsection of a section on door components. This modification is simply to move it.

Chuck Anderson

17

Comment

Proponent

Summary

Mod #

Section

Chapter

1715.9

3231 - **ACTION - APPROVED AS SUBMITTED-**

Establishes installation criteria (manufacturer's installation instructions), requires instructions available for inspector, provides for interchangeability of components, fasteners, etc., specifies C&C loads in accordance with 1609.1.1, and specifies factor of safety for testing.

Joseph Belcher

17

Comment

Proponent

Summary

Mod #

Section

Chapter

1715.9

3689 - **ACTION - NAR**

This modification is designed for the language set forth in Section 1715.8 to be consistent with regards to opening protection on soffit vents in Hurricane Prone Areas.

Michael Hemmer

17

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

1715.9

3855 - **ACTION - APPROVED AS MODIFIED**

Adds labeling requirements for soffits.

Joseph Belcher

17

Comment

Proponent

Summary

Mod #

Section

Chapter

1716.1

4411 - **ACTION -- TAC ON ACTION ON RANDY SHACKAFORDS COMENT TO THE MOD # A-2 = APPROVED AS MODIFIED**

Delete sec. 1716.1 in its entirety since referenced standard, D1761, is not relevant to joist hangers & content is in ASTM D 7147 05 so that should be referenced in sec. 2303.5.

Stuart Lewis

17

Comment

Proponent

Summary

Mod #

Section

Chapter

1801.1

3457 - **ACTION - APPROVED AS SUBMITTED-**

Exception in 1801.1 Scope is proposed to revise as follows

Exception: Buildings and structures located within the high velocity hurricane zone shall comply with the provisions of Sections 1816 through 1834 and 1805

Mohammed Shaikh

18

Comment

Proponent

Summary

Mod #

Section

Chapter

1801.1, 1804.4

3887 - **ACTION - APPROVED AS SUBMITTED-**

Florida specific modifications to Chapter 18, related to retaining flood provisions of the I Codes.

Rebecca Quinn

18

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

1808.2 Design for capacity and settlement

3606 -**ACTION - ASKED TO APPROVE COMMENT # A-1 - = ACTION - # A-1 APPROVED AS SUBMITTED-**

Upon identification of weak soils or soils having the possibility of differential settlement, require a design statement regarding either the remediation of the soils or indication within the building plan that the foundation system is designed with the understanding of the geologically hazard.

timothy moore

18

Comment

Proponent

Summary

Mod #

Section

Chapter

1816.1.7

3872 -**ACTION - NAR-**

Modify 1816.1.7 regarding the use of approved termite baits for new construction termite control to agree with FSS Chapter 482 which establishes requirements for new construction termite control contracts. Modification would change requirement for 5 year contract to 1 year plus 4 renewal years.

Sid Funk

18

Comment

Proponent

Summary

Mod #

Section

Chapter

1910.2

4469 -**ACTION - NAR**

Proposal adds additional fiber materials and adopts a new Acceptance Criteria.

Joseph Belcher

19

Comment

Proponent

Summary

Mod #

Section

Chapter

2002.2

3467 -**ACTION - NAR-= TAC DID NOT RECEIVE STANDARD**

This change updates the aluminum construction standard referenced to 2010.

John Kissell

20

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

2002.4

4216 -**ACTION - TABLED**

Proposal reduces concentrated load on purlins from 300 # to the OSHA required load for fixed ladders, 200#. The reduction applies to purlins only.

Joseph Belcher

20

Comment

Proponent

Summary

Mod #

Section

Chapter

2002.6

4279 -**ACTION - APPROVED AS SUBMITTED-**

Proposal to clarify wind load design criteria for sunrooms and to clarify intent of inclusion of AAMA Categories for sunrooms in code.

Joseph Belcher

20

Comment

Proponent

Summary

Mod #

Section

Chapter

2002.6

4312 -**ACTION - NAR**

This code change proposal updates the sunroom categories to be consistent with the revised edition of AAMA/NPEA/NSA 2100 10.

Daniel Walker

20

Comment

Proponent

Summary

Mod #

Section

Chapter

2003.1, 2003.2, 2003.3

3455 -**ACTION - NAR**

This proposed modification updates the references for HVHZ aluminum construction to the 2010 Aluminum Design Manual.

John Kissell

20

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

2003.9

4345 - **ACTION - MODIFIED - MODIFIED TWICE- ACTION = TABLED -ACTION - APPROVED AS MODIFIED -**

The proposal adds provisions for sunrooms in the HVHZ section of the code.

Joseph Belcher

20

Comment

Proponent

Summary

Mod #

Section

Chapter

2107.1

4063 - **ACTION - APPROVED AS SUBMITTED-**

Further modifies Florida Specific Amendment related to inspection and lap splice provisions of TMS 402/ACI 530/ ASCE 5 and TMS 602/ACI 530.1/ ASCE 6 to make them current with 2008 Editions of the documents.

Joseph Belcher

21

Comment

Proponent

Summary

Mod #

Section

Chapter

2107.5

4064 - **ACTION - APPROVED AS SUBMITTED/MODIFIED BECAUSE OF ELECTRONIC TRANSFER**

Updates existing Florida Specific Amendment to incorporate section and equation number changes of TMS 402/ACI 530/ASCE 5 2008.

Joseph Belcher

21

Comment

Proponent

Summary

Mod #

Section

Chapter

2108.1

4065 - **ACTION - APPROVED AS SUBMITTED-**

Updates references in an existing Florida Specific Amendment to account for changes in the referenced document.

Joseph Belcher

21

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

2109

4218 -**ACTION - TABLED RELATES TO ASCE-7-10, ACTION - APPROVED AS SUBMITTED**

This modification is a correlation to the modification that updates ASCE 7 to the 2010 Edition and introduces new ultimate design wind speed maps in the code.

T Stafford

21

Comment

Proponent

Summary

Mod #

Section

Chapter

2114.2

4066 -**ACTION - APPROVED AS SUBMITTED-**

Changes the order of the organizations developing the masonry standards to agree with the foundation code.

Joseph Belcher

21

Comment

Proponent

Summary

Mod #

Section

Chapter

2122

4135 -**ACTION - APPROVED AS AMENDED - TWICE -**

The modification updates the HVHZ provisions for the design and construction of reinforced unit masonry.

Joseph Belcher

21

Comment

Proponent

Summary

Mod #

Section

Chapter

1615.3, 2222.4.4

4370 -**ACTION -NAR**

The proposal revises the requirements for the deflection of structural roofing and siding made of formed metal sheets to be more consistent with current testing requirements in the Florida Building Code. The proposal also removes a reference to this requirement that is redundant in Chapter 22.

William Shoemaker

22

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

2209.2.1

3459 -**ACTION - ?**

Add additional current reference standard for composite steel deck design.

Thomas Sputo

22

Comment

Proponent

Summary

Mod #

Section

Chapter

2214 and 2222

3460 -**ACTION - APPROVED AS SUBMITTED-**

Update versions of design references for HVHZ within Sections 2214 and 2222.

Thomas Sputo

22

Comment

Proponent

Summary

Mod #

Section

Chapter

2214.3

3633 -**ACTION - APPROVED AS SUBMITTED-**

Section 2214.3 requires modification due to adoption of Manual of Steel Construction Thirteenth edition

Mohammed Shaikh

22

Comment

Proponent

Summary

Mod #

Section

Chapter

2218.3

3365 -**ACTION - NAR IN FAVOR OF 4248**

2218.3 Welding in the shop or field may only be done by AWS certified welders.

The code should read "AWS qualified" or "a welder whom has successfully performed a qualification test, per AWS D1.1 protocol and administered by an AWS certified welding inspector (CWI).

scott wilson

22

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

2218.3

4248 -**ACTION - APPROVED AS SUBMITTED-**

The proposal cleans up vague code language and more appropriately references the welder qualification requirements of the AWS Code rather than AWS certification of welders.

William Shoemaker

22

Comment

Proponent

Summary

Mod #

Section

Chapter

2222.3.3

4241 -**ACTION - NAR**

The proposal deletes a subsection in the cold formed steel construction section that belongs only in Section 2223.10 with respect to metal building systems.

William Shoemaker

22

Comment

Proponent

Summary

Mod #

Section

Chapter

2222.3.3 and 2223.10.1

3597 -**ACTION - NAR**

Cables and Rods shall not be used as bracing in Cold Formed and Pre Engineered steel buildings. This proposal is to delete the word "habitable" from these two sections of the code.

Mohammed Shaikh

22

Comment

Proponent

Summary

Mod #

Section

Chapter

2222.3.4

4251 -**ACTION - APPROVED AS SUBMITTED-**

The proposal deletes a subsection in the cold formed steel construction section that belongs only in Section 2223.10 with respect to metal building systems.

William Shoemaker

22

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

2223.1, 2223.2, 2223.3, 2223.4, 2223.5, 2223.6

4290 -**ACTION - AMENDED - APPROVED AMENDED WORKING APPROVED AS SUBMITTED - NAR**

The proposal updates responsibilities and document requirements for metal building systems to match the FL Board of Professional Engineers updated regulations with respect to engineers of record and delegated engineers.

William Shoemaker

22

Comment

Proponent

Summary

Mod #

Section

Chapter

2223.10.1

4274 -**ACTION - NAR**

This proposal seeks to clarify the intent of the applicability of the restriction on cables and rod bracing in metal buildings.

William Shoemaker

22

Comment

Proponent

Summary

Mod #

Section

Chapter

2223.10.2; 2223.10.5

4276 -**ACTION - APPROVED AS SUBMITTED-**

This proposal removes outdated terminology with respect to this form of construction.

William Shoemaker

22

Comment

Proponent

Summary

Mod #

Section

Chapter

2223.10.4

4278 -**ACTION - APPROVED AS SUBMITTED-**

This proposal deletes a redundant section that is already covered elsewhere in the code.

William Shoemaker

22

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

2223.11

4246 -**ACTION - NAR**

This proposal updates the certification requirement in Section 2223.11.2 to the new IAS AC472 accreditation program that replaced the discontinued AISC, Category MB Program.

William Shoemaker

22

Comment

Proponent

Summary

Mod #

Section

Chapter

2223.11.1

4243 -**ACTION - NAR**

This proposal would eliminate the requirements for inspections of metal building systems. While inspections can serve a useful purpose, it is inconsistent to require special inspections of metal building systems when other construction types are not subjected to this same scrutiny.

William Shoemaker

22

Comment

Proponent

Summary

Mod #

Section

Chapter

2223.8.2

4282 -**ACTION - WITHDRAWN**

This proposal deletes an unnecessary requirement that is covered by other required design standards.

William Shoemaker

22

Comment

Proponent

Summary

Mod #

Section

Chapter

2223.8.3

4284 -**ACTION - NAR**

This proposal deletes an unnecessary requirement that is covered by other required design standards.

William Shoemaker

22

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

2223.8.4

4288 - **ACTION - NAR**

This proposal deletes redundant requirements that are covered by other sections in the code.

William Shoemaker

22

Comment

Proponent

Summary

Mod #

Section

Chapter

Ch. 17 and 2223.11

4244 - **ACTION - NAR**

This proposal seeks to put more specificity into what the inspection requirements are in Section 2223.11.1 by invoking the appropriate inspection requirements of Chapter 17 of the IBC.

William Shoemaker

22

Comment

Proponent

Summary

Mod #

Section

Chapter

2303.5-

4414 **ACTION - ????**

Replace reference to section 1716.1 with reference to ASTM D7147, which replaces all content of section 1716.1.

Stuart

Lewis

23

Comment

Proponent

Summary

Mod #

Section

Chapter

2304, 2308

4219 **ACTION - ACTION - APPROVED AS SUBMITTED**

This modification is a correlation to the modification that updates ASCE 7 to the 2010 Edition and introduces new ultimate design wind speed maps in the code.

T Stafford

23

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

2304.11.6

3931 **ACTION - APPROVED AS SUBMITTED-**

Using base code language for termite protection.

J Glenn BASF

23

Comment

Proponent

Summary

Mod #

Section

Chapter

2314.0

4107 **ACTION - APPROVED AS SUBMITTED-**

This proposal updates the currently referenced standards to their current editions. In addition, it adds the ANSI/AF&PA Special Design Provisions for Wind and Seismic (SDPWS 2008).

Paul Coats

23

Comment

Proponent

Summary

Mod #

Section

Chapter

2404.1

3928 **ACTION - NAP**

Using base code language for Loads on vertical glass.

J Glenn BASF

24

Comment

Proponent

Summary

Mod #

Section

Chapter

2411.1

3580 **ACTION - APPROVED AS SUBMITTED-**

This modification moves section 2411.3.3.7 on the requirements for 'exterior safety glazed lite', to a new section 2411.1 General.

Jaime Gascon

24

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

2411.1.10

3470 **ACTION - APPROVED AS SUBMITTED-**

Delete Section 2411.1.10

William Dumbaugh

24

Comment

Proponent

Summary

Mod #

Section

Chapter

2411.1.11

3668 **ACTION - NAR - RECONSIDER BECAUSE OF ACTION ON 3669 -ACTION - APPROVED AS SUBMITTED**

The modification clarifies that 'comparative' analysis is allowed, as opposed to the used term 'rational' analysis when the fixed glazing product differs from the one approved.

Jaime Gascon

24

Comment

Proponent

Summary

Mod #

Section

Chapter

2603.8

3930 **ACTION - APPROVED AS SUBMITTED-**

Using base code language for termite protection for foam plastic.

J Glenn BASF

26

Comment

Proponent

Summary

Mod #

Section

Chapter

2603.8

3962 **ACTION - WITHDRAWN**

Using base code language for termite protection for foam plastic.

J Glenn BASF

26

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

3105.1

3961 **ACTION - APPROVED AS SUBMITTED-**

Use base code language for awning provisions

J Glenn BASF

31

Comment

Proponent

Summary

Mod #

Section

Chapter

3109

4416 **ACTION - NAR-**

Change language in the Code in relation to working within the CCCL.

James Battaglia

31

Comment

Proponent

Summary

Mod #

Section

Chapter

3109

4434 **ACTION - NAR-**

Clarifies language regarding exceptions to 100 year storm event design standards.

George Merlin

31

Comment

Proponent

Summary

Mod #

Section

Chapter

3109.1.1

4203 **ACTION - ACTION - APPROVED AS SUBMITTED-**

Modification corrects a formatting error in the 2007 Florida Building Code relating to construction of structures seaward of the coastal construction control line (CCCL).

Jack Glenn

31

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

3109.2

4234 **ACTION - APPROVED AS AMENDED BY SPECIAL OCCUPANCY TAC - APPROVED**

Add statutory definition for "Substantial improvement" to the code.

Jack Glenn

31

Comment

Proponent

Summary

Mod #

Section

Chapter

3113.1

3574 **ACTION - APPROVED AS AMENDED -**

When required by local government to reduce noise attenuation in new structure or addition to existing structure near an airport, applicant must provide documentation that structure meets the reduction requirement.

Kevin Gartland

31

Comment

Proponent

Summary

Mod #

Section

Chapter

3113.1 and R325.1

3511 **ACTION - WITHDRAWN**

When required by local government to reduce noise attenuation in new structure or addition to existing structure near an airport, applicant must provide documentation that structure meets the reduction requirement.

Kevin Gartland

31

Comment

Proponent

Summary

Mod #

Section

Chapter

3304.1.4

3959 **ACTION - APPROVED AS SUBMITTED-**

Restore reference to 1804.5 as the correct reference. Section 1803.5 Deals with soil investigation while Section 1804.5 deals with compacted fill. Delete the special inspector language.

J Glenn BASF

33

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

1.0

4099 **ACTION - APPROVED AS SUBMITTED**

This proposed modification updates the referenced standards to the latest versions referenced in the 2009 IBC, and corrects some out of date references.

Paul Coats

35

Comment

Proponent

Summary

Mod #

Section

Chapter

2002.4.1

4285 **ACTION - APPROVED AS SUBMITTED**

change AAF Guide to Construction in High Wind Areas from 2007 edition to 2010 edition

David Miller

35

Comment

Proponent

Summary

Mod #

Section

Chapter

35

4264 **ACTION - APPROVED AS SUBMITTED**

Updates AAMA referenced standards, ASTM glass and impact standards.

Chuck Anderson

35

Comment

Proponent

Summary

Mod #

Section

Chapter

3501

3890 **ACTION - APPROVED AS AMENDED**

Modification to correct citations to Code of Federal Regulations.

Rebecca Quinn

35

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

3501

4220 **ACTION - TABLED-ACTION - APPROVED AS SUBMITTED**

This modification updates ASCE 7 to the 2010 Edition.

T Stafford

35

Comment

Proponent

Summary

Mod #

Section

Chapter

AA

3458 **ACTION - NAR-**

This proposed modification updates the references for aluminum construction from the 2005 Aluminum Design Manual to the 2010 Aluminum Design Manual.

John Kissell

35

Comment

Proponent

Summary

Mod #

Section

Chapter

AAMA

4310 **ACTION - NAR**

This code change proposal updates the reference to AAMA/NPEA/NSA 2100 from 2002 to 2010.

Daniel Walker

35

Comment

Proponent

Summary

Mod #

Section

Chapter

AISC

3638 **ACTION - APPROVED AS SUBMITTED**

Chapter 35 AISC requires modification due to adoption of Manual of steel construction Thirteenth edition

Mohammed Shaikh

35

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

ASTM

4417 **ACTION - APPROVED AS SUBMITTED**

Add ASTM D 7147 05, update D1761 06 line.

Stuart Lewis

35

Comment

Proponent

Summary

Mod #

Section

Chapter

Referenced Standards

4034 **ACTION - APPROVED AS SUBMITTED**

Add AMCA 540 to Chapter 35 Referenced Standards

Amanda Hickman

35

Comment

Proponent

Summary

Mod #

Section

Chapter

Referenced Standards

4341 **ACTION - ACTION - APPROVED AS SUBMITTED**

Adds a reference to a new section addressing the use of the AAF Guide to Aluminum Construction in High Wind Areas in the HVHZ.

Joseph Belcher

35

Comment

Proponent

Summary

Mod #

Section

Chapter

Referenced Standards

4350 **ACTION - APPROVED AS MODIFIED, ADDED MASONRY ASSOCIATION OF FLORIDA**

Delete organization.

Joseph Belcher

35

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Building

SDI ANSI A250.13

4449 **ACTION - WITHDRAWN**

Delete ANSI A250.13 as a referenced standard

Kurt Roeper

35

Comment

Proponent

Summary

Mod #

Section

Chapter

New appendix

4391 **ACTION - NAR**

Add a new Appendix "XX" (Designation to be assigned)

Doug Harvey

2711

Comment

Proponent

Summary

Mod #

Section

Chapter

SubCode:

Existing Building

202

3901 **ACTION - APPROVED AS SUBMITTED-AS MODIFIED- IN # 3885**

Florida specific mods to retain I Code flood provisions. Defines 'local floodplain management ordinance' where communities will adopt FIRMs and higher stnds for NFIP Community Rating System. FBC requested statutory authority so that local higher stnds do not sunset every 3 years.

Rebecca Quinn

2

Comment

Proponent

Summary

Mod #

Section

Chapter

506.2

4419 **ACTION - NAR**

Adds clarity about non structural damage repairs.

James Battaglia

5

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Existing Building

606.5

4233 **ACTION - APPROVED AS SUBMITTED**

The proposal adds and Exception from impact protection for screen or removable vinyl and acrylic wind panels on exterior balconies and porches and relocates the HVHZ provision as an Exception.

Joseph Belcher

6

Comment

Proponent

Summary

Mod #

Section

Chapter

611.8.1.

3512 **ACTION - APPROVED AS MODIFIED - CORRECTED TABLE AS FOOT NOTES WERE LEFT OUT WHEN PUT INTO THE CODE-**

Notes are taken from Table R802.2.9.1 and are necessary to determine the actual uplift based on the roof span and overhang.

Jack Glenn

6

Comment

Proponent

Summary

Mod #

Section

Chapter

611.8.1.4

4470 **ACTION - APPROVED AS SUBMITTED**

Changes fastener specification for connector to that recommended by the manufacturer.

Randall Shackelford

6

Comment

Proponent

Summary

Mod #

Section

Chapter

611.8.1.6

4471 **ACTION - APPROVED AS SUBMITTED**

Changes fastener specification for connector to that recommended by the manufacturer.

Randall Shackelford

6

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Existing Building

1605

4444 **ACTION - APPROVED AS SUBMITTED & MODIFIED-TYPO-CORRECTION**

New provisions are added to specify uplift loads for gable rake overhang outlookers.

T Stafford

16

Comment

Proponent

Summary

Mod #

Section

Chapter

SubCode:

Mechanical

401.5

4035 **ACTION - APPROVED AS SUBMITTED**

Adds new standard: AMCA 550 to section 401.5

Amanda Hickman

4

Comment

Proponent

Summary

Mod #

Section

Chapter

501.2.2

4037 **ACTION - APPROVED AS SUBMITTED**

Add AMCA 550 to section 501.2.2

Amanda Hickman

5

Comment

Proponent

Summary

Mod #

Section

Chapter

Referenced Standards

4036 **ACTION - APPROVED AS SUBMITTED & AMENDED WITH CORRECT YEAR**

Add AMCA 550 to Referenced Standards

Amanda Hickman

15

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

202

3895 **ACTION - APPROVED AS SUBMITTED & MODIFIED CORRECT "PARTS"**

Florida specific mods to retain I Code flood provisions. Defines 'local floodplain management ordinance' where communities will adopt FIRMs and higher stnds for NFIP Community Rating System. FBC requested statutory authority so that local higher stnds do not sunset every 3 years.

Rebecca Quinn

2

Comment

Proponent

Summary

Mod #

Section

Chapter

202 Accessible

4014 **ACTION - APPROVED AS SUBMITTED**

Retain base code (IRC) language as it provides better direction

J Glenn BASF

2

Comment

Proponent

Summary

Mod #

Section

Chapter

202 Basic wind speed

4015 **ACTION - APPROVED AS SUBMITTED**

Retain base code (IRC) language as it provides better direction.

J Glenn BASF

2

Comment

Proponent

Summary

Mod #

Section

Chapter

202 Live load.

4016 **ACTION - WITHDRAWN**

Retain base code (IRC) language as it provides better direction.

J Glenn BASF

2

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

202 Shear Wall

4019 **ACTION - WITHDRAWN**

Retain base code (IRC) language.

J Glenn BASF

2

Comment

Proponent

Summary

Mod #

Section

Chapter

R202

4110 **ACTION - APPROVED AS SUBMITTED**

Clarifies terms related to roofs and to open areas. Current language has caused confusion at the permitting phase of sunroom construction projects.

Joseph Belcher

2

Comment

Proponent

Summary

Mod #

Section

Chapter

R202

4221 **ACTION - APPROVED AS SUBMITTED**

This modification is a correlation to the modification that updates ASCE 7 to the 2010 Edition.

T Stafford

2

Comment

Proponent

Summary

Mod #

Section

Chapter

R202

4313 **ACTION - NAR**

Updates the definition of Habitable Space to include revised information from AAMA/NPEA/NSA 2100 10 for sunrooms. This document now defines a Category IV sunroom as a non-habitable space.

Daniel Walker

2

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

301.2

4199 **ACTION - APPROVED AS SUBMITTED**

This proposal updates the component and cladding loads table for consistency with ASCE 7 05.

T Stafford

3

Comment

Proponent

Summary

Mod #

Section

Chapter

301.2.1.1

4198 **ACTION - APPROVED AS SUBMITTED**

Retain base code (IRC) language

J Glenn BASF

3

Comment

Proponent

Summary

Mod #

Section

Chapter

301.2.1.4.3

4196 **ACTION - APPROVED AS SUBMITTED**

Language is redundant as the exposure categories are previously defined

J Glenn BASF

3

Comment

Proponent

Summary

Mod #

Section

Chapter

301.2.2.4.2

4194 **ACTION - APPROVED AS SUBMITTED**

Add base code (IRC) language for clarity

J Glenn BASF

3

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

301.3

4097 **ACTION - NAR**

Retain the base code (IRC) language.

J Glenn BASF

3

Comment

Proponent

Summary

Mod #

Section

Chapter

308.6.1

4336 **ACTION - APPROVED AS SUBMITTED- MODIFICATION A-1 APPROVED**

Includes Tubular Daylighting Devices in definition of unit skylights

Chuck Anderson

3

Comment

Proponent

Summary

Mod #

Section

Chapter

308.6.9

4192 **ACTION - NAR**

Retain base code (IRC) language

J Glenn BASF

3

Comment

Proponent

Summary

Mod #

Section

Chapter

316.5.12

4118 **ACTION - APPROVED AS SUBMITTED**

Retain base code (IRC) language

J Glenn BASF

3

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

318.4

4106 **ACTION - APPROVED AS SUBMITTED**

Retain base code (IRC) language

J Glenn BASF

3

Comment

Proponent

Summary

Mod #

Section

Chapter

318.4

4116 **ACTION - WITHDRAWN**

Retain base code (IRC) language.

J Glenn BASF

3

Comment

Proponent

Summary

Mod #

Section

Chapter

R301

4222 **ACTION - APPROVED AS SUBMITTED**

This modification updates ASCE 7 to the 2010 Edition and introduces an ultimate design wind speed map.

T Stafford

3

Comment

Proponent

Summary

Mod #

Section

Chapter

R301.1

3863 **ACTION - APPROVED AS SUBMITTED**

Exception in section R301.1 is proposed to be revised to include Section R406 Foundation Dampproofing and Waterproofing of Non – HVHZ, since there is no provision in HVHZ.

Mohammed Shaikh

3

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

R301.1, 322.1.4, 322.1.7 & 322.1.9

3896 **ACTION - APPROVED AS SUBMITTED & MODIFIED IN A-1 -**

Florida specific modifications to Chapter 3, related to retaining flood provisions of the I Codes. Clarifies that structures seaward of the CCCL must also comply with R322 if also located in a flood hazard area.

Rebecca Quinn

3

Comment

Proponent

Summary

Mod #

Section

Chapter

R301.2.1.1

4108 **ACTION - APPROVED AS SUBMITTED & MODIFIED ADDRESSING "BASIC" WIND SPEED TERM V (USB)**

This modification replaces the outdated WPPC Guide to Wood Construction in High Wind Areas with the similar AF&PA WFCM Guide to Wood Construction in High Wind Areas.

Paul Coats

3

Comment

Proponent

Summary

Mod #

Section

Chapter

R301.2.1.1

4348 **ACTION - APPROVED AS SUBMITTED**

Updates the name of the organization responsible for the document.

Joseph Belcher

3

Comment

Proponent

Summary

Mod #

Section

Chapter

R301.2.1.1.2

4298 **ACTION - NAR- STANDRD NOT AVAIBLE**

This code change proposal updates the sunroom categories to be consistent with the revised edition of AAMA/NPEA/NSA 2100 10.

Daniel Walker

3

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

R301.2.1.1.2

4346 **ACTION - APPROVED AS SUBMITTED & MODIFIED CLEAR WIND SPEED**

Clarifies the application of AAMA 2100 and that the design is in accordance with the wind speeds and wind loads of the Florida Building Code.

Joseph Belcher

3

Comment

Proponent

Summary

Mod #

Section

Chapter

R301.2.1.2

3667 **ACTION - NAR -**

This section is modified to imply that all openings into a roof structure whether vertical or horizontal need to be protected in the event of a hurricane or high wind event from debris as well as wind and rain. This will reduce structural, wind, water, and personal belonging damage in such an event.

Michael Hemmer

3

Comment

Proponent

Summary

Mod #

Section

Chapter

R301.2.1.4

3666 **ACTION - APPROVED AS SUBMITTED**

Clarify the intent of Section R301.2.1.4 with regard to the 20% increase in uplift load regarding roof to wall connection.

Mo Madani

3

Comment

Proponent

Summary

Mod #

Section

Chapter

R301.2.4.1, R322.1.1

4404 **ACTION - APPROVED AS SUBMITTED -**

Allow use of ASCE 24 as an alternative in any flood hazard area, including A zones (see R322.2).

Christopher Jones

3

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

R301.2.4.1, R322.1.1

4406 **ACTION - WITHDRAWN**

Allow use of ASCE 24 as an alternative in Coastal A zones (where such areas are delineated, see R322.2).

Christopher Jones

3

Comment

Proponent

Summary

Mod #

Section

Chapter

R301.3, R301.5

4204 **ACTION - APPROVED AS SUBMITTED**

This modification deletes the prescriptive construction requirements in the code that do not apply to the design of buildings in Florida.

T Stafford

3

Comment

Proponent

Summary

Mod #

Section

Chapter

R322.2.4 and R322.3.3.1 (new)

3897 **ACTION - APPROVED AS SUBMITTED**

Florida specific modifications to the flood provisions retained in the residential code, to add provisions for pools that are found in Appendix G of the IRC.

The Workgroup recommended moving the provisions into the body of the code.

Rebecca Quinn

3

Comment

Proponent

Summary

Mod #

Section

Chapter

R322.3.3

4395 **ACTION - APPROVED AS SUBMITTED**

Add NFIP requirement that elevated buildings in V zones are to have the area underneath "free of obstruction."

Christopher Jones

3

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

R325.1

3575 **ACTION - APPROVED AS MODIFIED**

When required by local government to reduce noise attenuation in new structure or addition to existing structure near an airport, applicant must provide documentation that structure meets the reduction requirement.

Kevin Gartland

3

Comment

Proponent

Summary

Mod #

Section

Chapter

Table R301.2(3)

3651 **ACTION - NAR -**

Wind load values have been revised based on ASCE 7 10 provisions.

Joseph Hetzel

3

Comment

Proponent

Summary

Mod #

Section

Chapter

401.1

4093 **ACTION - NAR -**

Retain base code (IRC) language

J Glenn BASF

4

Comment

Proponent

Summary

Mod #

Section

Chapter

401.2

4094 **ACTION - NAR -**

Retain base code (IRC) language

J Glenn BASF

4

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

403.1

4095 **ACTION - NAR -**

Retain base code (IRC) language

J Glenn BASF

4

Comment

Proponent

Summary

Mod #

Section

Chapter

R401, R404

4223 **ACTION - APPROVED AS SUBMITTED**

This modification is a correlation to the modification that updates ASCE 7 to the 2010 Edition.

T Stafford

4

Comment

Proponent

Summary

Mod #

Section

Chapter

R401.1

3898 **ACTION - APPROVED AS SUBMITTED**

Second sentence in R401.1 requires foundations to meet the reqmts of R322 in addition to Chpt 4; thus #2 in the exception is not necessary. Other proposals for Chpt 44 will require meeting the reqmts of R322 if structures in HVHZ are also in flood hazard areas.

Rebecca Quinn

4

Comment

Proponent

Summary

Mod #

Section

Chapter

R402.4.2 Compressible or shifting soil

4280 **ACTION - NAR**

Upon identification of weak soils or soils having the possibility of differential settlement, require a design statement regarding either the remediation of the soils or indication within the building plan that the foundation system is designed with the understanding of the geologically hazard.

timothy moore

4

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

R404

4205 **ACTION - APPROVED AS SUBMITTED**

This modification is a correlation with the proposed modification that deletes the prescriptive construction requirements in the code that do not apply to the design of buildings in Florida.

T Stafford

4

Comment

Proponent

Summary

Mod #

Section

Chapter

501 and 502

3904 **ACTION - TABLE = NAR - IN FAVOR OF 4206**

Removes section which is applicable to areas with wind speeds less than 100 mph. Also reinstate I code format and reserve sections which are not applicable to FL. This will eliminate confusion and misuse of the code sections which are not applicable.

Jon Caudill

5

Comment

Proponent

Summary

Mod #

Section

Chapter

R502

4224 **ACTION - APPROVED AS SUBMITTED**

This modification is a correlation to the modification that updates ASCE 7 to the 2010 Edition.

T Stafford

5

Comment

Proponent

Summary

Mod #

Section

Chapter

R502, R503, R505

4206 **ACTION - APPROVED AS SUBMITTED (SUPPORT OVER 3904) APPROVED AS MODIFIED A TYPO) AS MODIFIED APPROVED - APPROVED AS MODIFIED**

This modification deletes the prescriptive construction requirements in the code that do not apply to the design of buildings in Florida.

T Stafford

5

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

R506.2.5

4472 **ACTION - NAR -**

Updates referenced organization and adds new ICC Acceptance Criteris.

Joseph Belcher

5

Comment

Proponent

Summary

Mod #

Section

Chapter

602

4032 **ACTION - TABLE UNTILL 4207 = ACTION = NAR IN FAVOR OF 4207**

Removes section which is applicable to areas with wind speeds less than 100 mph. Also reinstate I code format and reserve sections which are not applicable to FL. This will eliminate confusion and misuse of the code sections which are not applicable.

Jon Caudill

6

Comment

Proponent

Summary

Mod #

Section

Chapter

606.14.1

4103 **ACTION - APPROVED AS SUBMITTED**

Retain base code (IRC) language

J Glenn BASF

6

Comment

Proponent

Summary

Mod #

Section

Chapter

606.8.1

4102 **ACTION - APPROVED AS SUBMITTED**

Retain base code (IRC) language

J Glenn BASF

6

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

609.1.2

4098 **ACTION - APPROVED AS SUBMITTED**

Retain base code (IRC) language

J Glenn BASF

6

Comment

Proponent

Summary

Mod #

Section

Chapter

609.1.4

4104 **ACTION - APPROVED AS SUBMITTED**

Retain base code (IRC) language

J Glenn BASF

6

Comment

Proponent

Summary

Mod #

Section

Chapter

609.1.5

4105 **ACTION - NAR ????****ACTION - APPROVED AS SUBMITTED ????**

Retain base code (IRC) language

J Glenn BASF

6

Comment

Proponent

Summary

Mod #

Section

Chapter

612.6.1

4193 **ACTION - NAR**

Retain base code (IRC) language

J Glenn BASF

6

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

R602, R603, R604, R605, R611

4207 **ACTION - APPROVED AS SUBMITTED**

This modification deletes the prescriptive construction requirements in the code that do not apply to the design of buildings in Florida.

T Stafford

6

Comment

Proponent

Summary

Mod #

Section

Chapter

R602, R603, R606, R607, R608, R609, R611

4225 **ACTION - APPROVED AS SUBMITTED**

This modification is a correlation to the modification that updates ASCE 7 to the 2010 Edition.

T Stafford

6

Comment

Proponent

Summary

Mod #

Section

Chapter

R612.1

3578 **ACTION - APPROVED AS SUBMITTED**

Clarifies that the structural installation of windows and doors is part of the structural design and construction of walls and partitions as provided for in Chapter 6 of the FBC and IRC.

Dick Wilhelm

6

Comment

Proponent

Summary

Mod #

Section

Chapter

R612.11.4 [was FL613.7.5] Installation instruction

3579 **ACTION - APPROVED AS SUBMITTED**

ASTME2112 does not address Florida Specific CMU/stucco walls. Language is permissive.

Dick Wilhelm

6

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

R616

3582 **ACTION - APPROVED AS SUBMITTED**

Strikes prescriptive language which will be contained in its entirety in FMA/AAMA 100 07, Standard Practice for the Installation of Windows with Flanges or Mounting Fins in Wood Frame Construction.

Dick Wilhelm

6

Comment

Proponent

Summary

Mod #

Section

Chapter

R617

3858 **ACTION - APPROVED AS MODIFIED TO ADD PERMANTLIY MARKED**

Adds labeling requirements for manufactured soffit systems.

Joseph Belcher

6

Comment

Proponent

Summary

Mod #

Section

Chapter

R617.4

3860 **ACTION - APPROVED AS SUBMITTED**

Adds installation criteria, addresses permitted substitution of components, parts, or fasteners, specifies factor of safety for testing.

Joseph Belcher

6

Comment

Proponent

Summary

Mod #

Section

Chapter

702.3.4

4038 **ACTION - APPROVED AS SUBMITTED**

Retain base code (IRC) language as it provides better direction

J Glenn BASF

7

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

703.1

4040 **ACTION - APPROVED AS SUBMITTED**

Retain the base code (IRC) language while deleting the Florida Specific Amendment.

J Glenn BASF

7

Comment

Proponent

Summary

Mod #

Section

Chapter

703.10

4044 **ACTION - APPROVED AS SUBMITTED**

Retain the base code (IRC) language.

J Glenn BASF

7

Comment

Proponent

Summary

Mod #

Section

Chapter

703.10

4124 **ACTION - WITHDRAWN**

Retain base code (IRC) language

J Glenn BASF

7

Comment

Proponent

Summary

Mod #

Section

Chapter

703.11

4045 **ACTION - APPROVED AS SUBMITTED AND MODIFIED WITH ADDING "SHALL" BACK IN TO THE SECTION. MOVED TO RECONSIDER NAR FOR 4200 - NAR -**

Retain base code (IRC) language.

J Glenn BASF

7

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

703.11

4200 **ACTION - APPROVED AS SUBMITTED**

This proposal establishes a proper basis for vinyl siding applications with foam sheathing by applying appropriate adjustment factors to vinyl siding wind pressure rating.

T Stafford

7

Comment

Proponent

Summary

Mod #

Section

Chapter

703.4

4041 **ACTION - NAR -**

Retain base code (IRC) language as it provides better direction.

J Glenn BASF

7

Comment

Proponent

Summary

Mod #

Section

Chapter

R702

4208 **ACTION - APPROVED AS SUBMITTED**

This modification is a correlation with the modification that deletes the prescriptive construction requirements in the code that do not apply to the design of buildings in Florida.

T Stafford

7

Comment

Proponent

Summary

Mod #

Section

Chapter

R703

4226 **ACTION - APPROVED AS SUBMITTED**

This modification is a correlation to the modification that updates ASCE 7 to the 2010 Edition.

T Stafford

7

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

R703.1.1

3859 **ACTION - APPROVED AS SUBMITTED**

Provides reference to new labeling requirements.

Joseph Belcher

7

Comment

Proponent

Summary

Mod #

Section

Chapter

R703.12.3

4468 **ACTION - APPROVED AS SUBMITTED**

Proosal eliminates wind load provisions of AAMA 1402 which are contrary to the wind load provisions of the code.

Joseph Belcher

7

Comment

Proponent

Summary

Mod #

Section

Chapter

R703.8 Flashing

3584 **ACTION - APPROVED AS SUBMITTED AND MODIFIED**

Defines who is responsible for flashing instructions while also clarifying that door and window installation be in accordance with manufacturer's instructions and window and door flashing in accordance to R703.8 adds by reference, FMA/AAMA and FMA/WDMA installation protocols.

Dick Wilhelm

7

Comment

Proponent

Summary

Mod #

Section

Chapter

802

4165 **ACTION - TABLED FOR 4209 - NAR IN FAVOR OF 4209 AS MODIFIED**

Revise Sec. 802 to reserve roof/ceiling design and construction criteria for wind loads less than 100 mph and return section numbering to that used in the IRC.

Ann Stanton

8

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

802.1.6.3

4046 **ACTION - APPROVED AS SUBMITTED**

Retain the base code (IRC) language.

J Glenn BASF

8

Comment

Proponent

Summary

Mod #

Section

Chapter

802.1.6.5

4047 **ACTION - NAR -**

Retain base code (IRC) language

J Glenn BASF

8

Comment

Proponent

Summary

Mod #

Section

Chapter

802.2

4048 **ACTION - NAR FOR 4209**

Retain base code (IRC) language

J Glenn BASF

8

Comment

Proponent

Summary

Mod #

Section

Chapter

802.2.9.1

4473 **ACTION - NAR FOR 4209**

Deletes prescriptive roof tiedown requirements for windspeeds higher than 100 mph.

Randall Shackelford

8

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

804.1.1

4050 **ACTION - APPROVED AS SUBMITTED**

Retain base code (IRC) language.

J Glenn BASF

8

Comment

Proponent

Summary

Mod #

Section

Chapter

806.4

4051 **ACTION - APPROVED AS SUBMITTED MODIFIED TO REP FLORIDA CLIMENT ZONES APPROVED AS MODIFIED**

Retain base code (IRC) language.

J Glenn BASF

8

Comment

Proponent

Summary

Mod #

Section

Chapter

R802, R803, R804

4209 **ACTION - APPROVED AS SUBMITTED AND MODIFIED -**

This modification deletes the prescriptive construction requirements in the code that do not apply to the design of buildings in Florida.

T Stafford

8

Comment

Proponent

Summary

Mod #

Section

Chapter

R802, R803, R804

4227 **ACTION - APPROVED AS SUBMITTED AND MODIFIED**

This modification is a correlation to the modification that updates ASCE 7 to the 2010 Edition.

T Stafford

8

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

R4403

4229 **ACTION - APPROVED THEN NAR FOR 4230**

This modification is a correlation to the modification that updates ASCE 7 to the 2010 Edition.

T Stafford

9

Comment

Proponent

Summary

Mod #

Section

Chapter

1307.2.1

3869 **ACTION - NAR INCOMPLETE**

Add prescriptive for ground mounted units

Robert Cochell

13

Comment

Proponent

Summary

Mod #

Section

Chapter

1.0

4155 **ACTION - APPROVED AS SUBMITTED**

This proposal updates referenced AF&PA standards to their current editions.

Paul Coats

43

Comment

Proponent

Summary

Mod #

Section

Chapter

4301

3900 **ACTION - APPROVED AS SUBMITTED**

Florida specific modifications related to retaining flood provisions of the I Codes. This mod updates a reference to a FEMA publication and conforms the form of the references to the I Codes.

Rebecca Quinn

43

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

4301

4392 **ACTION - WITHDRAWN**

Correct and update references to FEMA technical bulletins.

Christopher Jones

43

Comment

Proponent

Summary

Mod #

Section

Chapter

4301

4393 **ACTION - WITHDRAWN**

Correct and update references to FEMA technical bulletins.

Christopher Jones

43

Comment

Proponent

Summary

Mod #

Section

Chapter

AAMA

4301 **ACTION - NAR - STANDARD NOT SUBMITTED NOT AVAILABLE**

Updates reference from AAMA/NPEA/NSA 2100 02 to AAMA/NPEA/NSA 2100 10.

Daniel Walker

43

Comment

Proponent

Summary

Mod #

Section

Chapter

AAMA

4306 **ACTION - NAR - STANDARD NOT AVAILABLE**

Updates reference from AAMA/NPEA/NSA 2100 02 to AAMA/NPEA/NSA 2100 10.

Daniel Walker

43

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

AISC

3671 **ACTION - APPROVED AS SUBMITTED**

New AISC reference standard is adopted thirteenth edition manual 2005.

This mod. is proposed to delete old manual references

Mohammed Shaikh

43

Comment

Proponent

Summary

Mod #

Section

Chapter

Chapter 43

3586 **ACTION - APPROVED AS SUBMITTED**

Adds FMA/AAMA 100 07, FMA/AAMA 200 09 and FMA/WDMA 250 10 installation protocols to Chapter 43, Referenced Standards.

Dick Wilhelm

43

Comment

Proponent

Summary

Mod #

Section

Chapter

NA

4342 **ACTION - APPROVED AS SUBMITTED**

Updates AAMA standards and ASTM impact standards

Chuck Anderson

43

Comment

Proponent

Summary

Mod #

Section

Chapter

R301.2.1.1

4291 **ACTION - APPROVED AS SUBMITTED**

Updating the 2007 edition of the AAF Guide to Aluminum Construction in High Wind Areas to the 2010 edition

David Miller

43

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

R4301

4231 **ACTION - APPROVED AS SUBMITTED**

This modification updates ASCE 7 to the 2010 Edition.

T Stafford

43

Comment

Proponent

Summary

Mod #

Section

Chapter

Referenced Standards

4340 **ACTION - APPROVED AS SUBMITTED**

Corrects incorrect code citation and adds new reference to new section addressing the use of the AAF Guide to Aluminum Construction in High Wind Areas in the HVHZ.

Joseph Belcher

43

Comment

Proponent

Summary

Mod #

Section

Chapter

Referenced Standards

4349 **ACTION - APPROVED AS SUBMITTED**

Update organization.

Joseph Belcher

43

Comment

Proponent

Summary

Mod #

Section

Chapter

4403.7.8

3843 **ACTION - APPROVED AS SUBMITTED AND MODIFIED (ORDER OF REFERENCE**

Clarification of required design Flood Loads for ASCE 7 in HVHZ

Mohammed Shaikh

44

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

4408.1.3

3670 **ACTION - APPROVED AS SUBMITTED**

This section requires modification due to adoption of 2005 Manual of Steel Construction, Thirteenth edition
Mohammed Shaikh

44

Comment

Proponent

Summary

Mod #

Section

Chapter

4409.1.4.7

4157 **ACTION - APPROVED AS SUBMITTED**

This proposal updates the currently referenced standards to their current editions.

Paul Coats

44

Comment

Proponent

Summary

Mod #

Section

Chapter

R4402.10.21, R4402.13.1.7

3701 **ACTION - APPROVED AS SUBMITTED**

Clarification

chris schulte

44

Comment

Proponent

Summary

Mod #

Section

Chapter

R4403

4230 **ACTION - APPROVED AS SUBMITTED AND MODIFIED SAME AS 4229 RECONSIDERED AND HAVE NAR FOR 4229**

This modification is a correlation to the modification that updates ASCE 7 to the 2010 Edition.

T Stafford

44

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

R4403.12

4305 **ACTION - APPROVED AS SUBMITTED AND MODIFIED OR AMENDED TOR LICENSED DESIGN PROFESSIONAL**

Proposal deletes an obsolete table no longer contained in ASCE 7 and permits the use of the AAF Guide to design screen enclosures.

Joseph Belcher

44

Comment

Proponent

Summary

Mod #

Section

Chapter

R4403.12

4333 **ACTION - APPROVED AS SUBMITTED AND AMENDED TO REMOVE 4403.12.1 HVHZ EXCEPT FOR WINDBREAKERS IN CODE CURRENTLY ACTION - APPROVED.**

Adds aluminum screen enclosure design pressure table from Chapter 22. Add windbreaker provisions from Chapter 16, Section 1622.

Joseph Belcher

44

Comment

Proponent

Summary

Mod #

Section

Chapter

R4403.13

3903 **ACTION - APPROVED AS SUBMITTED AND MODIFIED**

Florida specific modifications related to retaining flood provisions of the I Codes. These mod clarifies that structures and foundations seaward of the CCCL must also comply with R322 if also located in a flood hazard area.

Rebecca Quinn

44

Comment

Proponent

Summary

Mod #

Section

Chapter

R4403.13

4344 **ACTION - APPROVED AS SUBMITTED AND AMENDED AS MODIFIED IN 4345**

The proposal adds provisions for sunrooms in the HVHZ section of the code.

Joseph Belcher

44

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

R4403.16.1

3802 **ACTION - NAR -**

This code modification is meant to standardize a form of testing which is extremely necessary for soffit vents, soffit systems, and ridge vents in hurricane prone areas. This mod only revise Exception (b), the remaining text "unchanged"

Michael Hemmer

44

Comment

Proponent

Summary

Mod #

Section

Chapter

R4403.7.3.6.3

3730 **ACTION - APPROVED AS SUBMITTED -**

Correlates the HVHZ requirements on use of laminated glazing for glass railings used in the wind borne debris region with those of the 2009 IBC.

Jaime Gascon

44

Comment

Proponent

Summary

Mod #

Section

Chapter

R4403.9

4146 **ACTION - APPROVED AS SUBMITTED - AND APPROVED IN MOD 4143 - INTENT IS/WAS TO INCLUDE THIS IN THE HVHZ ZONE RESIDENTIAL CODE AND NON-HVHZ ?? APPROVED AS AMENDED**

ASCE 7 05 commentary states that high uplift may exist on rooftop equipment, but no methodology is given. Load calculations may vary by a large factor based on two methods given. This modification is to eliminate such differences and include uplift and revised lateral forces based on FIU research.

Arindam Gan Chowdhury

44

Comment

Proponent

Summary

Mod #

Section

Chapter

R4407

4137 **ACTION - APPROVED AS SUBMITTED (APPROVED IN 4135) FOR RESIDENTIAL CODE AMENDED - ACTION - APPROVED AS AMENDED**

The modification brings the section on reinforced unit masonry up to date with the national masonry standards.

Joseph Belcher

44

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Residential

R4408.9.3.3 and R4408.10.10.1

3866 **ACTION - NAR -**

Cables and rods shall not be used to brace Cold Formed (R4408.9.3.3) and Pre Engineered (R4408.10.10.1) steel buildings.

This proposal is to delete the word "habitable" from these two sections.

Mohammed Shaikh

44

Comment

Proponent

Summary

Mod #

Section

Chapter

R4410.2.1.11

3669 **ACTION - APPROVED AS AMENDED ALSO SEE 3668 - CON NOT DO RATIONAL ANALYSIS IN HVHZ - NEEDS TO BE COMPARATIVE**

The modification clarifies that 'comparative' analysis is allowed, as opposed to the used term 'rational' analysis when the fixed glazing product differs from the one approved.

Jaime Gascon

44

Comment

Proponent

Summary

Mod #

Section

Chapter

R4410.4

3529 **ACTION - NAR -**

As per the General portion of this section. We are requesting that the Soffit Vents and Gable Vents on Structures either have Specific Product Approvals or be protected with an Product Approved Shutter to prevent wind and water damage in that structure.

Michael Hemmer

44

Comment

Proponent

Summary

Mod #

Section

Chapter

New Appendix

4405 **ACTION - REFERENCE TO ICC 600 - WITHDRAWN BY BOAF**

Add a new Appendix "XX" (Designation to be assigned)

Doug Harvey

3316

Comment

Proponent

Summary

Mod #

Section

Chapter

SubCode:

Test Protocols

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Test Protocols

1.3, 8.5, 12.1.2

3535 **ACTION - NAR**

Clarifications of terms

chris schulte

1

Comment

Proponent

Summary

Mod #

Section

Chapter

10.4.8

3528 **ACTION - APPROVED AS SUBMITTED**

Deletion of reference to a nonexistent protocol TAS100(B), and clarifying the section.

Jaime Gascon

1

Comment

Proponent

Summary

Mod #

Section

Chapter

1.2

3542 **ACTION - NAR**

Clarification

chris schulte

1

Comment

Proponent

Summary

Mod #

Section

Chapter

12

3446 **ACTION - NAR**

Adds requirement for additional testing when original test is older than 10 years.

Jaime Gascon

1

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

Florida Department of Community Affairs
Building Codes and Standards
TAC & Commission Tracking Chart

Total Mods for this TAC:

Structural

TAC:

252

SubCode:

Test Protocols

6.3.1.1

3571 **ACTION - NAR -**

Clarification

chris schulte

1

Comment

Proponent

Summary

Mod #

Section

Chapter

12

3461 **ACTION - NAR -**

Adds requirement for additional testing when original test is older than 10 years.

Jaime Gascon

1

Comment

Proponent

Summary

Mod #

Section

Chapter

5.2.7

3464 **ACTION - APPROVED AS SUBMITTED**

Deletion of ASTM E283's standard year in the text of the protocol. Year of standard is already in chapter 35.

Jaime Gascon

1

Comment

Proponent

Summary

Mod #

Section

Chapter

13

3462 **ACTION - NAR -**

Adds requirement for additional testing when original test is older than 10 years.

Jaime Gascon

1

Comment

Proponent

Summary

Mod #

Section

Chapter

AS = Approved as Submitted

AM = Approved as Modified

NAR = No Affirmative Recommendation

W = Withdrawn

I = Insufficient (incomplete or does not meet criteria)

TAC Recommendations

